

Chief Fire Officer/Chief Executive M Yates QFSM MA MCGI DMS MIFireE

Hereford & Worcester Fire and Rescue Service Headquarters 2 Kings Court Charles Hastings Way Worcestor WR5 IJR Tel 0845 12 24454 Fax 01905 357 466 Web www.hwfire.org.uk

Sue Garratt

Licensing & Support/Services Manager

Worcestershire Regulatory Services

Bromsgrove District Council 13 DEC 2013

PO Box 866 WORCESTER

WR1 9DP

Telephone

0845 12 24454

Your reference

My reference

DGH/JEA

Please ask for

Darren Hunt

Date

11 December 2013

Dear Madam

Re: Licensing Act 2003 - Review of Statement of Licensing Policy

SERVICES

With reference to your letter dated 2 December 2013 in respect of the above, I confirm I have reviewed the document and would comment as follows :-

Para 6:2

Remove

"plans will not be required to be submitted to any particular scale"

Insert

"plans should be submitted to a recognised scale, i.e. 1:50 or 1:100, or 1:150

or 1:200"

After

"any feature relevant to the application ..."


Insert

"to include details of any passive or active fire safety measures including location of smoke detectors, call points, other fire alarm equipment, fire

extinguishers, emergency lights and fire exits"

I trust that you find the above points constructive and should you wish to discuss these or any other licensing matters further, then please do not hesitate in contacting my lead officer for Licensing, Darren Hunt on 01905 368225 (dghunt@hwfire.org.uk).

Yours faithfully



Mike Cunningham Group Manager Community Risk

