

The Authority requires that a condition be placed on the license that a full Event Management Plan (EMP) and Fire Risk Assessment are submitted for comment and to be approved by the Authority and other regulatory bodies a minimum of 2 months prior to any events taking place.

The applicant and other responsible persons should be aware that the Regulatory Reform (Fire Safety) Order 2005 requires that a fire risk assessment is carried out to identify fire hazards and the general fire precautions necessary to ensure the safety of persons. This will include an assessment of the adequacy of existing measures to control risk in the event of fire; for example, the adequacy of existing escape routes and the maximum numbers of persons that could be safely evacuated in the event of fire, the adequacy of emergency escape lighting and escape signage, the adequacy of the means for detecting and raising the alarm, the suitability of means for extinguishing fire, measures for action to be taken in the event of fire, and measures relating to the instruction and training of stewards and other employees.

---